

# SPECIFICATION FOR PRODUCT

Part name: TERMINAL BLOCK

Part NO: E/6A

**Customer P/N:** 

Date: 2023-03-27

### **Seller Confirmation**

Written by	Qunyan.zhang
Checked by	Youndy
Approved by	Eric

### **Customer Confirmation**

Project Audit	
Structure	
Audit	
Security	
Certification	
Quality	
Approval	

Seller: Shanghai Utility Electrical Co., Ltd

Add: 1759# Zhongshan Road ,Shanghai

Tel: 021-61478435 Fax:021-61478103

E-Mail: Marketing@china-utl.com


Customer: Customer P/N:

Seller:Utility Electrical Co., Ltd Part No: E/6A


### **Revision for E/6A**

Item No	Edition	Part Revised	Date Revised
1	Α	put in file	2023-03-27
2			
3			
4			
5			
6			
7			
8			

# 1. TYPE: E/6A



# 2.DRAWING&SIZES



### 3. BOM TABLE

			SURFACE OF	QUANTITY
ITEM.	PART NAME	MATERIAL	CONTACT	(PCS)
(1)	HOUSING	PA66 UL94 V-0	/	1
(2)	JUMP RING	SUS301	/	1
(3)	FIXED PIECE	SUS301	1	1

# **4.WORKING CONDITION:**

OPERATING TEMPERATURE: -40℃~+105℃

RELATIVE HUMIDITY: 5%~95%

5. PACKAGE: Tightly Sealed